
Department of Property & Procurement

Government of the United States Virgin Islands 3274 ESTATE RICHMOND, CHRISTIANSTED, U. S. VIRGIN ISLANDS 00820 8201 SUB BASE, SUITE 4, ST. THOMAS, U. S. VIRGIN ISLANDS 00802

ST. CROIX MAIN OFFICE: 340.773.1561 | ST. THOMAS MAIN OFFICE: 340.774.0828 ST. CROIX FAX: 340.773.0986 ST. THOMAS FAX: 340.777.9587





October 17, 2016

AMENDMENT #2 IFB016DOHT16 (C) Qualified Contractors to furnish all labor, tools, equipment, machinery and supply for the Renovation of the Department of Health Eldra Shulterbrandt Annex Facility on St. Thomas, Virgin Islands.

DELETE:

Old Bid Schedule and Alternate

INSERT:

New Bid Schedule and Alternate

Questions and Answers

New Shed Plans

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED

BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS AMENDMENT WITH THEIR BID PROPOSAL.

ADDENDUM /SECTION 2: BID SCHEDULE FOR CONSTRUCTION

DEPARTMENT OF HEALTH: ELDRA SHULTERBRANDT ANNEX FACILITY		CONTRACTOR'S NAME:				
Grant No. 1	D12AP00350 (VI-CIP-2012-4)					
GOVERNMENT OF THE UNITED STATES VIRGIN ISLANDS - September 9, 2016		ADDRE	SS:			
SA ANNA'S	RETREAT, ST. THOMAS					
ECTION 2: ANNEX BASE BID SCHEDULE FOR CONSTRUCTION- AMENDENDMENT		TELEPHONE:				
ALL BIDDERS MEASUREMEN	ARE REQUIRE TO A MANDATORY PRE BID MEETING AND INSPECTION OF PROPERTY PRIOR TO SUBNTS.	BMITTING	BIDS. FIELD VE	RIFY ALL QUANTITI	ES AND	
Item No.	Description	Est.	Units	Unit Price	TOTAL	
	CONCRETE ACCESS PATHWAY FOR DELIVERIES	1	LS			
	■ LAUNDRY FACILITY VENTILATION SYSTEM	1	LS			
	■ BATHROOM FIXTURES - UPGRADE 2 TUBS OF COMMERCIAL UNITS	1	LS			
	EXTERIOR SHED ROOF -EXTEND EXISTING SHED ROOF /PER DRAWINGS	1	LS			
	REMOVE EXISTING CERAMIC TILE, INSTALL(FASTEN) 1/2" CEMENT BOARD; LEVEL AND GROUT AND INSTALL AND GROUT NEW TILES TO MATCH EXISTING	750	SF			
	■ LAUNDRY EQUIPMENT - COMMERCIAL-GRADE WASHER FRONT END LOADER	2	Allowance	\$20,000.00		
	■ LAUNDRY EQUIPMENT - COMMERCIAL-GRADE DRYERS	2	Allowance	\$20,000.00		
	CHANGE ALL AC FILTERS THROUGH OUT ANNEX	1	LS			
	REPAIR LEAK AT AC DUCT AT FRONT AREA COMPLETE AND REPLACE ALL STAINED CEILING TILES TO MATCH EXISTING	1	LS			
	ANNEX BASE BID CONSTRUCTION TOTAL	Name of the last				
	The total amount of this proposal is Based Bid (Annex)on the Contractor's Estimate	e of quan	fifies and is as f	ollows:		
\$					- 12 K	
	Bidder's Signature			Date		

ADDENDUM II/SECTION 2: BID SCHEDULE FOR CONSTRUCTION

DRES							
EPHO	NE:						
st.	Units		TELEPHONE:				
		Unit Price	TOTAL				
1	LS						
1	LS						
1	LS						
1	LS						
			(35.40 years)				
ate of	quantities of	and is as follows:					
	1 1	1 LS	1 LS				

Section 2: Bid Sheet/Price Schedule for Construction/EldraShulterbrandtAnnexFacility/Grant No. D12AP00350 (VI-CIP-2012-4)Page1

AMENDMENT

GOVERNMENT OF THE UNITED STATES VIRGIN ISLANDS DEPARTMENT OF PUBLIC WORKS

Through

DEPARTMENT OF PROPERTY AND PROCUREMENT

for the DEPARTMENT OF HEALTH

REQUEST FOR PROPOSAL/GENERAL CONTRACTORS VIRGIN ISLANDS GOVERNMENT DEPARTMENT OF HEALTH RFP

Renovation at Eldra Shulterbrandt **Annex Facility** IFB-016-DOH16 (Grant No. D12AP00350 (VI-CIP-2012-4)) 6A Anna's Retreat, St. Thomas, U.S. Virgin Islands

Pre-bid Conference was held on Wednesday September 28, 2016 at the Department of Property and Procurement, St. Thomas, U.S. Virgin Islands with a site visit at the above mentioned property. From that meeting, this Amendment No. 1 seeks to clarify the following questions and general comments from the Proposers.

- Question... Will the contractor be able to use the water and power of the facility?
 Answer... Contractor will be granted the use of the water and power of the facility.
- Question... What kind of washer and dryer will be used in the facility, gas or electric?
 Answer... Unless otherwise mentioned, the washer and dryer for the annex facility will be electric.
- 3. **Question...** Drawings call for three (3) dryers and No washer upfront loaded while schedule call for two (2) of each, which prevails?
 - <u>Answer</u>... As per the bid sheet, contractors shall bid on two (2) commercial grade washers front end loader and two (2) commercial grade dryers with a total allowance of \$40,000.00.
- 4. Question... Bid sheet mentions "Concrete access pathway for deliveries", what is the details (length, width, thickness, reinforcement) of the pathway?
 - Answer... The concrete access pathway is to be constructed of 5'-0' wide x 68'-0" long x 4" thick concrete with 10x10-10/10 welded wire mesh on a compacted gravel base. Pathway shall connect the main entrance with the service entrance to the Kitchen. It shall wrap around the building and be "L" shaped.
- 5. **Question...** Can the contractors be furnished with some details for the Exterior Shed Roof Extension mentioned in the construction document?

Answer... Yes! See attached detail of Exterior Shed Roof Extension.

The due date for submitting Proposals has been changed to October 31, 2016

